

Infrared Hydrocarbon Gas Detector PointWatch Eclipse® Model PIRECL



DESCRIPTION

Y E A R
5
WARRANTY

The Pointwatch Eclipse® Model PIRECL is a diffusion-based, infrared combustible gas detector that provides continuous, fixed monitoring of flammable hydrocarbon gases from 0 to 100% Lower Flammable Limit (LFL). Standard device outputs include an electrically isolated 4-20 mA signal with HART communication protocol, and RS-485 serial communication. Serial communication protocols supported include MODBUS and ASCII. An optional relay output board with two programmable alarm relay outputs and one fault relay output is available.

support include MODBUS and ASCII. An optional relay output board with two programmable alarm relay outputs and one fault relay output is available.

Ideally suited for protection of challenging on/offshore oil and gas facilities and other downstream hydrocarbon applications, the PointWatch Eclipse is globally certified for use in Class I, Divisions 1 and 2, and Zones 1 and 2 hazardous areas. In addition, the stainless steel construction, sapphire optics, and modular design all combine to deliver industrial grade hardness along with easy installation and the lowest cost of ownership available.

The PointWatch Eclipse is capable of detecting hundreds of flammable hydrocarbon gases and vapors. The Eclipse is performance certified to methane, propane, ethylene, and butane, and is shipped from the factory set and calibrated to one of these gases. Numerous additional operating parameters are programmable via digital communication or the optional hand-held communicator.



FEATURES AND BENEFITS

- Superior optics protection system.
- No undisclosed failure modes.
- SIL 2 model certified to IEC 61508 by *exida*®
- Routine calibration not required.
- Explosion-proof, stainless steel housing with tethered weather protection baffle.
- Integral wiring compartment eliminates need for external junction boxes.
- Built-in tri-color LED eliminates need for external display module.
- Built-in optional relay package eliminates need for external relay output module.
- EQP models available.
- Non-interfering HART communication capability.
- Optional Intrinsically Safe HART communication port
- Optional hand-held HART communicator enables field configuration and calibration.
- Heated sapphire optics deliver long-lasting, high performance detection capability.
- Immune to damage from exposure to constant background gases or to high gas concentrations.
- FM, CSA, DNV/MED, DEMKO and CE (including ATEX 94/9/EC) certifications.
- Certified to FM/CSA Div. 1 and DEMKO Ex d, e protection standards for maximum versatility.
- Gas performance verification by FM/CSA/DEMKO.
- Factory set and calibrated to methane, propane, ethylene, or butane.

SPECIFICATIONS

Input Voltage	24 Vdc nominal. Operating range is 18 to 32 Vdc. Ripple cannot exceed 0.5 volt P-P.
Power Consumption	4.0 watts nominal @ 24 Vdc 7.5 watts maximum @ 24 Vdc 10 watts maximum @ 32 Vdc.
Short Circuit Current	Isc: 5.4 amperes. Isc (fuse): 3.1 amperes. Power Supply Max Voltage: Um = 250V.
Warmup Time	Two minutes from cold power-up to normal mode; 1 hour minimum recommended.
Current Output Relays (Opt.)	Linear 4-20 mA (current source/sink, isolated/ non-isolated) rated at 600 ohms maximum loop resistance @ 24 Vdc operating voltage.
Temperature Range	Operating: -40°C to +75°C (-40°F to +167°F). Storage: -55°C to +85°C (-67°F to +185°F).
Humidity	0 to 99% R.H. (Det-Tronics verified). 5 to 95% R.H. (FM/CSA/DEMKO verified).
Detection Range	0 to 100% LFL standard. Other ranges are configurable.
Detectable Gases	Most flammable hydrocarbon vapors are detectable. Eclipse is performance certified to methane, propane, ethylene, and butane, and is shipped from the factory set and calibrated to one of these gases. For detection of other gases, configuration using HART, MODBUS, or EQP system software, and device calibration are required.
Device Configuration	Configuration parameters include tag number, measurement range, signal processing algorithm, alarm levels, and other selectable parameters.
Response Time in Sec. (With Methane Applied and Baffle Installed)	T50 T60 T90 With Hydrophobic Filter: 4.4 4.8 8.2 Testing based on EN 60079-29-1. See manual 95-8526 for other gases and other performance standards.
Alarm Setpoint Range	Low Alarm: 5 to 60% LFL High Alarm: 5 to 60% LFL. Note: Low alarm range for EQP model is 5-40% LFL.
Accuracy	±3% from 0 to 50% LFL, ±5% from 51 to 100% LFL.
Self-Diagnostic Test	All critical tests performed once per second.
Detector Housing Material	316 stainless steel (CF8M).
Conduit Entry Options	Two entries, 3/4 inch NPT or 25 mm.
Wiring Terminals	Field wiring screw terminals are UL/CSA rated for up to 14 AWG wire, and are DIN/VDE rated for 2.5 mm ² wire.
Shipping Weight (Approximate)	11.5 pounds (5.2 kg).
Dimensions	L = 9.3 in, W = 5.2 in, H = 4.6 in.

Certifications

FM & CSA:	Class I, Div. 1, Groups B, C & D (T4) with intrinsically safe output for HART communication in accordance with control drawing 007283-001. Class I, Div. 2, Groups A, B, C & D (T3C). Performance certified to Methane, Propane, Ethylene, & Butane in accordance with FM 6310/6320, ANSI/ISA 12.13.01, and CSA C22.2 No. 152. Tamb = -40°C to +75°C. Acidic atmospheres excluded. Conduit seal not required.
CE:	Conforms to: Low Voltage Directive: 2006/95/EC, EMC Directive: 2004/108/EC, ATEX Directive: 94/9/EC.
IEC:	IECEX ULD 04.0002X Ex de IIC T4-T5 Gb -- OR -- Ex de [ib] IIC T4-T5 Gb (with HART communication port) T5 (Tamb -50°C to +40°C) T4 (Tamb -50°C to +75°C) -- OR -- IECEX ULD 04.0002X Ex d IIC T4-T5 Gb -- OR -- Ex d [ib] IIC T4-T5 Gb (with HART communication port) T5 (Tamb -55°C to +40°C) T4 (Tamb -55°C to +75°C) IP66/IP67.
ATEX:	CE 0539 Ex II 2 G Ex de IIC T4-T5 Gb -- OR -- Ex de [ib] IIC T4-T5 Gb (with HART communication port) DEMKO 01 ATEX 129485X. (Performance certified to Methane, Propane, Ethylene, & Butane in accordance with EN 60079-29-1.) T5 (Tamb -50°C to +40°C) T4 (Tamb -50°C to +75°C) -- OR -- CE 0539 Ex II 2 G Ex d IIC T4-T5 Gb -- OR -- Ex d [ib] IIC T4-T5 Gb (with HART communication port) DEMKO 01 ATEX 129485X. (Performance certified to Methane, Propane, Ethylene, & Butane in accordance with EN 60079-29-1.) T5 (Tamb -55°C to +40°C) T4 (Tamb -55°C to +75°C) IP66/IP67.
DNV:	Certificate No. A-11023
MED:	Certificate No. MED-B-5866 Certificate No. MED-D-1508
SIL:	All Safety-Certified PIRECL models are certified compliant to: IEC61508: 2000 SIL 2 certified.

Specifications subject to change without notice.

Det-Tronics, the DET-TRONICS logo, and Eclipse are registered trademarks or trademarks of Detector Electronics Corporation in the United States, other countries, or both. Other company, product, or service names may be trademarks or service marks of others.

©Copyright Detector Electronics Corporation 2012. All rights reserved.



Detector Electronics Corporation

6901 West 110th Street • Minneapolis, Minnesota 55438 USA

Operator: (952) 941-5665 or (800) 765-FIRE

Customer Service: (952) 946-6491 • Fax (952) 829-8750

http://www.det-tronics.com • E-mail: det-tronics@det-tronics.com